

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. DIS - 01Date: 27/07/26

It is certified that an inspection team headed by Narendra Dugtal Sampling Assistant
 (Name of Officers
 with designation) from UJS Haldwani Uttarakhand (Name of
 Department/Office) inspected the Divine International School Bilaspur U.P
 (Name & Address of
 the School) on 24/07/26 and found that the Divine International School Bilaspur
 (Name of school) has safe
 drinking water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.

The above valid for a period of 27/07/2027

Signature with Seal :

Name :

Designation :


/s/ Swendra Singh
Swendra Singh
chemist

Authorized Signatory
 Sub Divisional Level
 Water Quality Testing & Monitoring Laboratory
 UJS Haldwani (Nainital)

To

The Principal
Divine International School
Bilaspur Uttar Pradesh
 (Name & Address of the Institution)

Principal
Divine International School
Bilaspur (Rampur) U.P.





Sub Divisional Level Water Testing Laboratory

UTTARAKHAND JAL SANSTHAN HALDWANI, NAINITAL

Name of the Customer/ Organization:	Divine International School Village-Gada, P.O Bilaspur Distt:- Rampur Uttar Pradesh	Sample Description	Divine International School Village-Gada, P.O Bilaspur Distt:- Rampur Uttar Pradesh
Type of Water (Surface water/Ground water)	Drinking -Water	Start of analysis	24-07-2026
Sample Code:	DIS-01	Sample collected By	Customer
Sample Receiving Date and Time:	24.07.2026 04:00 PM	Date of Issue Report	27-07-2026

Water Quality Test Report

Testing Details

S.N.	Parameters	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Results
1	Colour (Hazen units)	5	15	1
2	Odour (Agreeable)	Agreeable	Agreeable	Agreeable
3	pH@25*c	6.5 to 8.5	No relaxation	7.61
4	Alkalinity as CaCO ₃ (mg/l)	200	600	25
5	Turbidity (NTU)	1	5	0.36
6	Total dissolved solid (mg/l)	500	2000	56.8
7	Chloride (mg/l)	250	1000	4.9
8	Total hardness (mg/l)	200	600	40
9	Calcium(as ca) (mg/l)	75	200	10
10	Magnesium (mg/l)	30	100	3.65
11	Total coliform (MPN/100ML)	Absent	Absent	ABSENT
12	E.Coli (MPN/100ML)	Absent	Absent	ABSENT

[Signature]
CHEMIST,
SDLWQTML,
UJS Haldwani (Nainital)

Sub Divisional Level
Water Quality Testing & Monitoring Laboratory
UJS Haldwani (Nainital)

[Signature]
Principal
Divine International School
Bilaspur (Rampur) U.P.

[Signature]
Lab In-charge
SDLWQTML
UJS Haldwani (Nainital)

TECHNICAL MANAGER
Sub- Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS Haldwani (Nainital)

